Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. JNP/26/1008 Dated: 18/09/2026

It is certified that an inspection team headed by ...Deepak Pandey JE UPJN(R)

(Name of Officers with designation) from ...U.P.J.N Jaunpur.....PHED

inspected the S.J. Public School makhadumpur kohari Jalalpur Jaunpur

(Name & Address of the school) on 18/09/2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. JNP/26/1008 dated 18/09/2026

of District level water Anyelsis lab Jaunpur (PHED Lab) certified that

the S.J public school makhadumpur kohari Jalalpur Jaunpur (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 18/09/2027

Signature with Seal: .....
Name : ...
Designation : ...
Name & Address of the Office / Department : ...

सहायक अभियन्ता
जल निगम(ग्रामीण)जौनपुर
E.E. Distt UPJN (R) Jaunpur

To S.J. Public School makhadumpur
Kohari Jalalpur Jaunpur
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

District Level Water Analysis Laboratory,
Uttar Pradesh Jal Nigam,(Rural),Kalichabad
Sultanpur road District-Jaunpur -222002

T C - 12452

FormatNo.-7.5 F-01

TEST REPORT

Report No.	JNP/26/1008	Date–18.09.2026	S.No – 1008	Page No. 1	Page1/1

Customer Details

Office Name and Address	S. J. Public School Makhadumpur Kohari Jalalpur Jaunpur
Ref Letter No &Date	

Basic Details of sample

District	Jaunpur	Block	Jalalpur
Gram Panchayat	Makhadumpur	Village	Makhadumpur Kohari jaunpur
Habitation	Makhadumpur	Location	Makhadumpur
Water Source	Submer cible	Sample No.	JNP/26/1008
Quantity of Sample	1000 ml	Date of S.C.	08/09/2026
Receiving Date	08/09/2026	S.Collector	Navneet yadav
Sample Depositor	Navneet yadav	Sampling Method -	IS3025 (Part 1)
Analysis Start Date	10/09/2026	Analysis Complete Date	10/09/2026

Environmental Condition

Temperature	25 ± 3 °C	Relative Humidity	50±15%

Technical Data of Analysis

S. No.	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values as perIS10500:2012		Ref .Method of Analysis
			Acceptable Limit	Permissible Limit	
	2	3	4	5	6
1	pH@25°C	7.93	6.5	8.5	IS3025(Part11):2022,ElectrometricMethod
2	Turbidity(NTU)	0.72	1	5	IS3025(Part10):1984 : 2021 (Nephelometric method)
3	Total Dissolved Solids(mg/L)	342.2	500	2000	IS3025(Part16):1984 : 2023(Gravimetric method)
4	Chloride(mg/L)	23	250	1000	IS3025(Part32):1988: 2021(Argentometric method)
5	Total Alkalinity(mg/L)	320	200	600	IS3025(Part23):1986 : 2021 (Potentiometricandindicatormethod)
6	Total Hardness(mg/L)	192	200	600	IS3025(Part21):2009: 2021(EDTAmethod)
7	Calcium(mg/L)	52.8	75	200	IS3025(Part40):1991 :2019(EDTATitrimetricmethod)
8	Magnesium(mg/L)	15	30	100	IS3025(Part46):1994: 2019(Volumetricmethod)
9	Sulphate (as SO_4)	12.56	200	400	APHA 24th Edition – 4500-SO4 Method E (Turbidmetric Method ,2023)
10	Nitrate(as NO_3)mg/L	11.04	45	No relaxation	APHA 24th Edition – 4500-NO3 Method B (UV Screening Method ,2023)
11	Fluoride (as F)mg/L	0.329	1.0	1.5	APHA 24th Edition- 2023, 4500-F (C. Ion Selection Electrode Method)
12	Iron(as Fe)mg/L	BDL	1.0	No relaxation	APHA 24th Edition – 3500- Fe Method B (Phenanthroline ,2023)

Note: -
1. This certificate refers only to the particular sample(S) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored upto15days (in case of non perishable items only) from the date of issue of test reports unless otherwise specified.
5. This report valid for submitted sample only.

Report View by

Shruti
(Shruti Mishra)
Authorized signatory

Laboratory Contact details-Email- districtlabjaunpur@gmail.com Mob- 8127284974

End of Test Report